

REGULAR MEETING

September 09, 2019
6:30 p.m.

MEMORANDUM

G.1 Approve Change Order Summary Report – August 2019

Mr. Sederlund

RECOMMENDED MOTION: “That the Chippewa Valley Schools Board of Education approve the 2018 Bond Issue Change Order Summary Report for the month of August 2019.”

RATIONALE: This work consists of changes to existing contracts for the purpose of owner requested work, deducts, code compliance, or hidden conditions on the construction and equipment projects. All amounts are within the contingency budget allocation.

This report was reviewed with the Building and Site Sub-Committee on Monday, September 9, 2019 and funding will come from the 2018 Building and Site Fund.

CHIPPEWA VALLEY SCHOOLS
2010 Bond Issue Program

CHANGE ORDER SUMMARY #1

August 2019

PROJECT	CONTRACTOR	C.O.#	DESCRIPTION	AMOUNT
Contingency (design revision, owner request, hidden condition)				
A DHS	Best Asphalt	1	Increase sub-base material due to poor existing soil conditions. This work was recommended by Testing Engineers & Consultants	\$ 69,409.00
CVHS	Motor City Fencing	2	Repair and adjust existing gates at Tennis Courts	\$ 830.30
Total Amount of Summary				\$ 70,239.30

Construction Contingency Budget	\$	3,332,658.00
Previous Construction Contingency Costs	\$	-
Current Construction Contingency Costs	\$	<u>70,239.30</u>
Construction Contingency Balance	\$	3,262,418.70

MEMORANDUM

BARTON MALOW COMPANY

DATE: August 9, 2019
TO: Scott Sederlund, Chippewa Valley Schools
FROM: Douglas Madden., Barton Malow Company
RE: Chippewa Valley Schools
2018 Bond Issue Program
Dakota High School
Tennis Court Replacement

Barton Malow has reviewed the proposal from the contractor listed below for the Dakota High School Tennis Court Replacement Project and found everything to be in order. Therefore, it is the recommended motion that the Board of Education awards a change order to the existing contract as presented.

<u>Bid Category</u>	<u>Contractor</u>	<u>Amount</u>
Asphalt Paving	Best Asphalt	\$69,409.00

The existing conditions were tested and evaluated by a soils engineer, Testing Engineers & Consultants (TEC). The recommendation from TEC was to installing a Geogrid fabric on the existing base soils along with an addition 6" of 21AA base material. This work will be funded from the project contingency.

Please feel free to contact me at the Barton Malow field office at 248.219.4295, if you should have any questions or comments regarding this recommendation.

COPY: Ken Hauer, Chippewa Valley Schools
Daryl Dombrow, Barton Malow Co.
Brian Smilnak, Wakely Associates
File